



中国国家强制性产品认证证书

证书编号: 2003010307102903

委托人名称、地址

Siemens AG, I BT LV
Siemensstrasse 10 93055 Regensburg, Germany

生产者(制造商)名称、地址

上海西门子线路保护系统有限公司
上海市金山区张堰镇金张支路90号

生产企业名称、地址

上海西门子线路保护系统有限公司
上海市金山区张堰镇金张支路90号

产品名称和系列、规格、型号

剩余电流保护断路器

5SU9 356-1KK..., 5SU9 356-1KN..., 5SU9 356-1CR..., 5SU9 356-1CS..., 5SU9 156-7KK..., 5SU9 156-7VK..., 5SU9 356-7VK..., 5SU9 356-7KK..., 5SU9 356-7KN..., 5SU9 356-7CR..., 5SU9 354-7KK..., 5SU9 354-8KK, 5SU9 356-7CS... 详见附件

产品标准和技术要求

GB 16917.1-2003, GB 16917.22-2008

上述产品符合强制性产品认证实施规则
CNCA-01C-012:2007的要求, 特发此证。

发证日期: 2010年11月22日 有效期至: 2015年05月19日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2003年12月30日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0332088



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010307102903

NAME AND ADDRESS OF THE APPLICANT

Siemens AG, I BT LV
Siemensstrasse 10 93055 Regensburg, Germany

NAME AND ADDRESS OF THE MANUFACTURER

Siemens circuit Protection systems Ltd., Shanghai
No. 90 Jinzhang Zhi Road, Zhangyan Town, Jinshan District, Shanghai
201514, P. R. China

NAME AND ADDRESS OF THE FACTORY

Siemens circuit Protection systems Ltd., Shanghai
No. 90 Jinzhang Zhi Road, Zhangyan Town, Jinshan District, Shanghai
201514, P. R. China

NAME, MODEL AND SPECIFICATION

Residual Current Operated Circuit-breaker

5SU9 356-1KK..., 5SU9 356-1KN..., 5SU9 356-1CR..., 5SU9 356-1CS..., 5SU9 156-7KK..., 5SU9 156-7VK..., 5SU9 356-7VK..., 5SU9 356-7KK..., 5SU9 356-7KN..., 5SU9 356-7CR..., 5SU9 354-7KK..., 5SU9 354-8KK, 5SU9 356-7CS... see the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 16917.1-2003, GB 16917.22-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-01C-012:2007).

Date of issue: Nov. 22, 2010 Date of expiry: May. 19, 2015

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Dec. 30, 2003

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 0332088



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2003010307102903

纸号: 332088

5SU9 356-1KK..., 5SU9 356-1KN..., 5SU9 356-1CR..., 5SU9 356-1CS...,
5SU9 156-7KK..., 5SU9 156-7VK..., 5SU9 356-7VK..., 5SU9 356-7KK...,
5SU9 356-7KN..., 5SU9 356-7CR..., 5SU9 354-7KK..., 5SU9 354-8KK...,
5SU9 356-7CS...

Ue= AC230V;

In= 6A,10A,16A,20A,25A,32A,40A,50A,63A;

瞬时脱扣类型: C 型, D 型;

I Δ n=0.01A, 0.03A, A 型, AC 型;

极数: 1P+N;

电子式;

5SU9 356-1KK..., 5SU9 356-1KN..., 5SU9 356-1CR..., 5SU9 356-1CS...,

5SU9 156-7KK..., 5SU9 156-7VK..., 5SU9 356-7VK..., 5SU9 356-7KK...,

5SU9 356-7KN..., 5SU9 356-7CR..., 5SU9 356-7CS...

I Δ m=6000A; Ics=Icn= 6000A;

5SU9 354-7KK..., 5SU9 354-8KK...;

I Δ m=10000A; Ics=7500A; Icn= 10000A;

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

